

POST CONSTRUCTION ELEVATION CERTIFICATE/FLOODPROOFING CERTIFICATE

Assessor's Parcel No. 140-052-21	BUILDING OWNER Buckwalter, Richard D.	COMMUNITY NUMBER 060178A
----------------------------------	--	-----------------------------

INSTRUCTIONS: The registered professional engineer, architect, surveyor or community permit official completes Section I below. Section II may be completed by any of the professionals listed at the beginning of Section II, or by a similarly qualified local permit official or by a local permit official relying on official permit records. Print or type the information on this form. This form is to be used for new (POST-FIRM) construction and for substantial improvements to existing structures in Zones A1-A30, AO, AH, A99 and V1-V30 and existing (PRE-FIRM) buildings to be rated under POST-FIRM rules and rates.

SECTION I

PROPERTY LOCATION (lot and block numbers and address if available) 868 Cypress Avenue		
FIA MAP PANEL ON WHICH PROPERTY IS LOCATED 0002	FIA MAP ZONE IN WHICH PROPERTY IS LOCATED AO	
FIA MAP EFFECTIVE DATE January 19, 1978	BASE FLOOD ELEVATION AT THE BUILDING SITE (Est. Depth 2')	
START OF CONSTRUCTION DATE August, 1946	Name and Title Tom Nolan, City Engineer	PHONE (with Area Code) (415) 897-4341
ADDRESS 901 Sherman Avenue, Novato, CA 94947		
<i>Tom Nolan</i> (Signature)		9/21/83 (Date)

SECTION II

INSTRUCTIONS

Complete only the Elevation Certification unless the building has been floodproofed at least to the base flood elevation. If floodproofing is used, complete only the Floodproofing Certification. The Elevation Certification may be completed by a registered professional engineer, architect, or surveyor. The Floodproofing Certification may only be completed by a registered professional engineer or architect.


ELEVATION CERTIFICATION

ZONES A, A1-30, A-99, AH: I certify that the building at the property location described above has the lowest floor (including basement) at an elevation of _____ feet, NGVD (mean sea level) and the average grade at the building site is at an elevation of _____ feet, NGVD.

ZONES V, V1-V30: I certify that the building at the property location described above has the bottom of the lowest floor beam at an elevation of _____ feet, NGVD (mean sea level), and the average grade at the building site is at an elevation of _____ feet, NGVD.

ZONE AO: I certify that the building at the property location described above has the lowest floor (including basement) elevated 2 feet above the highest adjacent grade. This meets , does not meet the community's requirement for new construction. Structure finish floor elev. = 19.83 Highest Adjacent Grade = 17.7 Elevations based on National Geodetic Vertical Data.

CERTIFIER'S NAME Dale A. White
TITLE Licensed Land Surveyor
ADDRESS 1620 Grant Ave Novato, CA 94947
<i>Dale A. White</i> (Signature)
Sept. 21, 1983 (Date)



The insurance agent attaches the second copy of the completed form to the flood insurance policy application for new (POST-FIRM) construction or substantial improvements. Be sure that the second copy is certified.